



Unpaved areas within and adjacent to the security fence shall be leveled and compacted after which 2 layers of 6 mil black plastic weed barrier and three inches (3") of crushed gravel shall be added. This gravel area shall extend in all directions a minimum of two feet (2') beyond the security fence. Bank run gravel is not acceptable.

Note:
 Drawing not to scale. Site Layout is one of several possible layouts and is for illustrative purposes only.

Dry-prime pump may be substituted with a generator with the approval of the Engineer.

Asphalt parking and drive shall be constructed in accordance with Standard Detail G-23 or as directed by the Engineer.

	APPROVED	REVISIONS		ST. MARY'S COUNTY METROPOLITAN COMMISSION STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES
	 C. I. FREDERICK JR., P.E. CHIEF ENGINEER	DATE	INITIALS	
	DATE: 7/1/09	6/18/09	J.E.C.	Submersible Wastewater Pumping Station Site Plan
				STANDARD NO. PS-12