


Notes:

1. Meter shall be from an approved manufacturer.
2. Meter connections shall be flanged.
3. Meter pit shall be sized to accommodate the meter with adequate room for maintenance.
4. Plastic meter box covers shall not be permissible.
5. All copper lines shall be type "K" (Federal Spec. WW-T-799).
6. Meter pit shall be constructed of concrete, ABS plastic or an approved equal.
7. Larger frame and lid meter box cover may be used with the approval of the Engineer.
8. Meter shall be placed as close as possible to the property line.
9. Meter shall not be placed in areas subject to vehicular traffic without the approval of the Engineer.
10. Meter located within 3 feet of a driveway shall have the lid assembly encased and supported with concrete.



<p><b>APPROVED</b></p> <p><i>M. C. Hollander</i></p> <p>M. C. HOLLANDER, P.E. CHIEF ENGINEER</p> <p>DATE: <u>7/11/19</u></p>	<b>REVISIONS</b>		<p>ST. MARY'S COUNTY METROPOLITAN COMMISSION STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES</p>
	DATE	INITIALS	
	6/18/09	J.E.C.	
	8/31/10	J.E.C.	
	2/5/19	J.E.C.	<p>TYPICAL SETTING METERS 1 1/2" and 2"</p> <p><b>STANDARD NO. W-6</b></p>