


NOTES:

CLEANOUT SHALL BE INSTALLED UTILIZING THE APPLICABLE STANDARD DETAIL AS DIRECTED BY THE ENGINEER.

SERVICE VALVE ASSEMBLY SHALL BE INSTALLED IN ACCORDANCE WITH METCOM STANDARD P-1.

DEPTH OF PRESSURE SEWER SHALL NOT EXCEED 5'6".

PRECAST SEWER BLOCK SHALL BE USED ON VERTICAL WYE.



APPROVED

M. C. Hollander

M. C. HOLLANDER, P.E.
CHIEF ENGINEER

DATE: 7/11/19

REVISIONS

| DATE | INITIALS |
|---------|----------|
| 6/18/09 | J.E.C. |
| 1/8/19 | J.E.C. |
| | |

ST. MARY'S COUNTY
METROPOLITAN COMMISSION
STANDARDS FOR PUBLIC WATER, SEWER
AND INCIDENTAL STRUCTURES

LOW PRESSURE SEWER
CONNECTION TO NEW OR EXISTING
GRAVITY SEWER SERVICE

STANDARD NO. P-10