



POST INDICATOR VALVE (P.I.V.) SHALL BE PLACED ON ALL FIRE SERVICE LINES.

VALVE SHALL BE INSTALLED IN ACCORDANCE WITH METCOM STANDARD W-2.

VALVE SHALL BE PROVIDED WITH P.I.V. RISER MOUNTING PLATE AFFIXED TO VALVE BONNET.

P.I.V. SHALL BE PLACED AT THE PROPERTY LINE OR AS CLOSE TO THE MAIN AS PRACTICAL AND OUTSIDE OF THE FALL LINE OF THE STRUCTURE SERVED.

P.I.V. SHALL OPERATE COUNTER CLOCKWISE TO SHUT.

OPERATING NUT SHALL BE 1 1/4" SQUARE.

P.I.V. OPERATING WRENCH SHALL BE PROVIDED AND AFFIXED TO THE VALVE BODY IN A MANNER THAT SHALL ENSURE THE VALVE IS LOCKED OPEN UNTIL NECESSARY TO CLOSE.

MODIFICATION OF P.I.V. FOR HEIGHT ADJUSTMENT SHALL BE IN ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS.

P.I.V. SHALL BE A MINIMUM OF 36" FROM THE BURY LINE TO THE TOP OF THE OPERATING NUT.

MAXIMUM HEIGHT SHALL NOT EXCEED 48" .

P.I.V. SHALL BE FACTORY PAINTED RED.

	<u>APPROVED</u>	<u>REVISIONS</u>		ST. MARY'S COUNTY METROPOLITAN COMMISSION STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES
	 C. I. FREDERICK JR., P.E. CHIEF ENGINEER	DATE	INITIALS	
	DATE: 7/1/09	6/18/09	J.E.C.	
				STANDARD NO. W-15