



**NOTES:**

MANHOLE SHALL BE CONSTRUCTED UTILIZING ALL OF THE DETAIL NOTES AND STANDARDS OF THE PRECAST LINE MANHOLE. METCOM STANDARD S-1 OR S-2 AS APPLICABLE.

BREACHING OF MANHOLE SHALL ONLY BE DONE BY CORE DRILLING AND USE OF THE A-LOK® TYPE GASKET OR APPROVED EQUAL.

PROVIDE SMOOTH DOWNWARD SLOPING CHANNEL FROM FORCE MAIN TO GRAVITY SEWER.

CHANNEL SHALL BE CONSTRUCTED IN ACCORDANCE WITH METCOM STANDARD S-7.

	<b>APPROVED</b>	<b>REVISIONS</b>		<b>ST. MARY'S COUNTY METROPOLITAN COMMISSION</b> STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES
	 C. I. FREDERICK JR., P.E. CHIEF ENGINEER  DATE: <u>7/1/09</u>	DATE	INITIALS	
		6/18/09	J.E.C.	