




NOTES:  
ROADWAY AND  
PAVEMENT REPAIR SHALL  
BE IN ACCORDANCE WITH  
THE APPROVING  
JURISDICTION OR OWNER.

WITHIN PAVED  
RIGHT-OF-WAY

GREEN AREA



\*ALL LOOSE MATERIAL SHALL BE REMOVED FROM THE TRENCH BOTTOM  
PRIOR TO BEDDING PIPE.  
AGGREGATE MATERIAL SHALL BE PLACED AGAINST UNDISTURBED SOIL.  
TRENCH FOUNDATION WHEN REQUIRED SHALL BE SPECIFIED BY THE ENGINEER.

	<b>APPROVED</b>	<b>REVISIONS</b>		<b>ST. MARY'S COUNTY METROPOLITAN COMMISSION</b> STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES
	 C. I. FREDERICK JR., P.E. CHIEF ENGINEER	DATE	INITIALS	
	DATE: 7/26/10	6/18/09	J.E.C.	TYPICAL BEDDING AND BACKFILL FOR PIPE AND APPURTENANCES <b>STANDARD NO. G-6</b>
		7/26/10	J.E.C.	