


HYDRANT LEAD SHALL BE 6" D.I. PIPE ONLY.
 HYDRANT LEAD SHALL NOT EXCEED 25 FEET IN LENGTH.
 HYDRANT AUXILIARY VALVE SHALL BE BOLTED DIRECTLY TO THE TEE.
 ALL FITTINGS, HARDWARE, ASSOCIATED CONCRETE AND AGGREGATES SHALL BE IN ACCORDANCE WITH THE APPROPRIATE MATERIAL SPECIFICATIONS, SECTION.
 HYDRANT SHALL BE ROTATED AS DIRECTED BY ENGINEER.
 HYDRANT SHALL BE 4' TO 6' BURY DEPTH.
 USE OF MECHANICAL JOINT RETAINER GLANDS MAY BE USED INSTEAD OF THRUST BLOCKING WITH THE APPROVAL OF THE ENGINEER.



APPROVED
M. C. Hollander
 M. C. HOLLANDER, P.E.
 CHIEF ENGINEER
 DATE: 7/11/19

REVISIONS	
DATE	INITIALS
6/18/09	J.E.C.
2/5/19	J.E.C.

**ST. MARY'S COUNTY
 METROPOLITAN COMMISSION
 STANDARDS FOR PUBLIC WATER, SEWER
 AND INCIDENTAL STRUCTURES**

**FIRE HYDRANT SETTING
 (TYPICAL)**

STANDARD NO. W-1