



Plastic pit setter shall have a minimum diameter of 24" and shall be round.

Plastic pit setter shall have a minimum height of 30" without the meter lid frame installed.

Plastic pit setter shall not be placed in an area subject to vehicular traffic.

Meter placed in an area subject to vehicular traffic will require the approval of the Engineer.

Meter located within 3 feet of a driveway shall have the lid assembly encased and supported with concrete.

All materials and associated aggregates shall be in accordance with the Material Specifications Section as most recently revised.

All copper connections shall be flared.

HDPE connections shall be compression type with stainless steel insert

Copper setter shall be in accordance with MetCom Standard Detail W-13.

Corporation stop may be tapped directly into a ductile iron main with the approval of the Engineer.



APPROVED

M. C. Hollander

M. C. HOLLANDER, P.E.
CHIEF ENGINEER

DATE: 7/11/19

REVISIONS	
DATE	INITIALS
6/18/09	J.E.C.
7/23/10	J.E.C.
2/5/19	J.E.C.

ST. MARY'S COUNTY
METROPOLITAN COMMISSION
STANDARDS FOR PUBLIC WATER, SEWER
AND INCIDENTAL STRUCTURES

TYPICAL INSTALLATION OF SINGLE METER
SETTING FOR DOMESTIC USE
WITH DOMESTIC SPRINKLER SYSTEM

STANDARD NO. W-4B