


NOTES:

SHALLOW MANHOLE SHALL BE CONSTRUCTED UTILIZING ALL OF THE DETAIL NOTES AND STANDARDS OF THE PRECAST LINE MANHOLE. METCOM STANDARD S-1

MANHOLE SHALL BE 60" IN DIAMETER

ACCESS WAY SHALL BE 30" IN DIAMETER

FORCE MAIN SHALL PASS THROUGH THE CENTER OF THE MANHOLE.



APPROVED

C.I.F.

C. I. FREDERICK JR., P.E.
CHIEF ENGINEER

DATE: *7/1/09*

REVISIONS	
DATE	INITIALS
6/18/09	J.E.C.

ST. MARY'S COUNTY
METROPOLITAN COMMISSION
STANDARDS FOR PUBLIC WATER, SEWER
AND INCIDENTAL STRUCTURES

LOW PRESSURE SEWER DETAIL
AIR RELIEF / VACUUM
VALVE SETTING

STANDARD NO. P-8