



1. CHAIN LINK FABRIC SHALL BE #9 GAUGE, 2" MESH.
2. CHAIN LINK FABRIC SHALL BE GALVANIZED WITH A BLACK VINYL COATING. FABRIC SHALL BE PLACED ON THE OPPOSITE SIDE OF THE SECURE AREA.
3. GATE SHALL BE 2" GALVANIZED PIPE AND SHALL BE OF WELDED CONSTRUCTION.
4. GATE POST SHALL BE 3 1/2" N.P.S. IN DIAMETER.
5. GATE SHALL BE CONSTRUCTED WITH LATCH ASSEMBLY AND GATE ANCHOR ROD.
6. ALL POSTS AND RAILS SHALL BE ROLL FORMED HOT-DIPPED GALVANIZED STANDARD WEIGHT PIPE.
7. ALL FITTINGS SHALL BE HOT-DIPPED GALVANIZED.
8. GATES SHALL BE HUNG TO SWING AWAY FROM THE SECURE AREA.
9. HINGES SHALL BE DESIGNED IN A MANNER THAT DOES NOT ALLOW THE GATES TO BE LIFTED OFF.
10. GATE WITHOUT THREE STRANDS OF BARBED WIRE MAY BE SUBSTITUTED WITH GATE FRAME AND FABRIC 8' IN HEIGHT WITH THE APPROVAL OF THE ENGINEER.

	<u>APPROVED</u>	<u>REVISIONS</u>		<b>ST. MARY'S COUNTY METROPOLITAN COMMISSION</b> STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES
	 C. I. FREDERICK JR., P.E. CHIEF ENGINEER	DATE	INITIALS	
	DATE: 7/1/09	6/18/09	J.E.C.	