



**NOTES:**

- VALVE BOX SHALL BE SCREW ADJUSTABLE WITH AN ARCH PATTERN BASE
- VALVE BOX SHALL BE GRAY CAST IRON WITH A 1/2" SHAFT AND COATED WITH COAL TAR EPOXY.
- VALVE BOX SHALL HAVE THE WORD "SEWER" CAST IN THE COVER.
- ARCH PATTERN VALVE BOX SHALL NOT BE USED FOR VALVES OVER 3".
- BLOCKING SHALL BE SOLID BUILDING BLOCKS OR CONCRETE.
- ARCH OPENINGS IN VALVE BOX SHALL BE COVERED WITH ROOFING FELT TO PREVENT THE ENTRANCE OF BACKFILL MATERIAL.
- CONCRETE COLLARS, 18"X6" SHALL BE PROVIDED FOR ALL VALVE BOXES.

	<b>APPROVED</b>	<b>REVISIONS</b>		<b>ST. MARY'S COUNTY METROPOLITAN COMMISSION</b> STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES
	 C. I. FREDERICK JR., P.E. CHIEF ENGINEER	DATE	INITIALS	
	DATE: 7/1/09	6/18/09	J.E.C.	