


Notes:

1. Minimum fall across the manhole shall be 0.2' unless approved by the Engineer.
2. Angle between inlet and outlet pipe shall not be less than 90 degrees.
3. All brick shall be solid sewer manhole brick.
4. Brick in channel invert shall be laid on edge.
5. Concrete channels may be substituted for brick with the approval of the Engineer.



APPROVED

CIF

C. I. FREDERICK JR., P.E.
CHIEF ENGINEER

DATE: 7/1/09

REVISIONS	
DATE	INITIALS
6/18/09	J.E.C.

**ST. MARY'S COUNTY
METROPOLITAN COMMISSION**

**STANDARDS FOR PUBLIC WATER, SEWER
AND INCIDENTAL STRUCTURES**

**MANHOLE CHANNELS
(TYPICAL)**

STANDARD NO. S-6