


DIAMETER OF CASING SHALL BE DETERMINED BY THE ENGINEER.

PIPE SUPPORTS SHALL BE THE PROPER SIZE TO CENTER THE PIPE IN THE CASING.

CASING SHALL BE INSTALLED LEVEL UNLESS OTHERWISE DIRECTED BY THE ENGINEER.

WELDS ON CASING SECTIONS SHALL BE AROUND THE ENTIRE CIRCUMFERENCE OF THE CASING PIPE.



APPROVED

C.I.F.

C. I. FREDERICK JR., P.E.
CHIEF ENGINEER

DATE: 7/1/09

REVISIONS	
DATE	INITIALS
6/18/09	J.E.C.

**ST. MARY'S COUNTY
METROPOLITAN COMMISSION**
STANDARDS FOR PUBLIC WATER, SEWER
AND INCIDENTAL STRUCTURES

CASING ASSEMBLY USING
PREFABRICATED PIPE SUPPORTS
(TYPICAL)

STANDARD NO. G-7