


Unpaved areas within and adjacent to the security fence shall be leveled and compacted after which 2 layers of 6 mil black plastic weed barrier and three inches (3") of crushed gravel shall be added. This gravel area shall extend in all directions a minimum of two feet (2') beyond the security fence. Bank run gravel is not acceptable.

**Note:**  
 Drawing not to scale. Site Layout is one of several possible layouts and is for illustrative purposes only.

Dry-prime pump may be substituted with a generator with the approval of the Engineer.

Asphalt parking and drive shall be constructed in accordance with Standard Detail G-23 or as directed by the Engineer.



**APPROVED**

C. I. FREDERICK JR., P.E.  
 CHIEF ENGINEER

DATE: 7/1/09

**REVISIONS**

DATE	INITIALS
6/18/09	J.E.C.

ST. MARY'S COUNTY  
 METROPOLITAN COMMISSION  
 STANDARDS FOR PUBLIC WATER, SEWER  
 AND INCIDENTAL STRUCTURES

Typical Site Plan For Suction Lift &  
 Submersible Wastewater  
 Pumping Station

**STANDARD NO. PS-9**