



NOTE:
TRENCH SHALL BE COMPACTED TO A MINIMUM 95% OF DENSITY.

ALL EXPOSED EDGES OF EXISTING BITUMINOUS PAVEMENT AND SURFACE OF GRAVEL BASE SHALL BE PRIMED BEFORE THE BITUMINOUS MIXTURE IS PLACED.

PRIOR TO PLACING BITUMINOUS PAVEMENT, ALL UTILITY STRUCTURES SHALL BE BROUGHT TO GRADE. BACKFILL AROUND UTILITY STRUCTURES WITH STRUCTURAL FILL.

	APPROVED	REVISIONS		ST. MARY'S COUNTY METROPOLITAN COMMISSION STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES
	 C. I. FREDERICK JR., P.E. CHIEF ENGINEER	DATE	INITIALS	
	DATE: 7/1/09	6/18/09	J.E.C.	TYPICAL REPAIR OF BITUMINOUS SURFACES STANDARD NO. G-9A