


1. CHAIN LINK FABRIC SHALL BE #9 GAUGE, 2" MESH.
2. CHAIN LINK FABRIC SHALL BE GALVANIZED WITH A BLACK VINYL COATING. FABRIC SHALL BE PLACED ON THE OPPOSITE SIDE OF THE SECURE AREA.
3. CHAIN LINK FABRIC SHALL BE TWISTED AND BARBED TOP AND BOTTOM.
4. END, CORNER POST SHALL BE 3 1/2" IN DIAMETER.
5. LINE POST SHALL BE 2 1/2" IN DIAMETER.
6. ALL POSTS AND RAILS SHALL BE ROLL FORMED HOT-DIPPED GALVANIZED STANDARD WEIGHT PIPE.
7. ALL FITTINGS SHALL BE HOT-DIPPED GALVANIZED.
8. 1 5/8" O.D. BRACE RAIL SHALL BE ATTACHED TO CORNER, END OR GATE POST AND TO ADJACENT LINE POST
9. TRUSS ROD SHALL BE A MINIMUM OF 3/8", ROUND ROD WITH AN ADJUSTABLE TURNBUCKLE.
10. TENSION WIRE SHALL BE #7 GAUGE, GALVANIZED.
11. FENCE SHALL FOLLOW THE CONTOUR OF THE GROUND.
12. GATE SHALL BE INSTALLED IN ACCORDANCE WITH STANDARD DETAIL G-22.



**APPROVED**

*CIF*  
C. I. FREDERICK JR., P.E.  
CHIEF ENGINEER

DATE: *7/1/09*

**REVISIONS**

DATE	INITIALS
6/18/09	J.E.C.

**ST. MARY'S COUNTY  
METROPOLITAN COMMISSION  
STANDARDS FOR PUBLIC WATER, SEWER  
AND INCIDENTAL STRUCTURES**

**TYPICAL CHAIN LINK FENCE  
8 FT. HEIGHT**

**STANDARD NO. G-21**