



NOTE:

1. GLASS LINED D.I.P. OR APPROVED EQUAL SHALL BE USED WHEN THE DEPTH OF MAIN IS 18' OR GREATER
2. TYPE "D" CONNECTION SHALL NOT BE USED FOR NEW CONSTRUCTION. (RETROFIT ONLY)

	APPROVED	REVISIONS		ST. MARY'S COUNTY METROPOLITAN COMMISSION STANDARDS FOR PUBLIC WATER, SEWER AND INCIDENTAL STRUCTURES
	 C. I. FREDERICK JR., P.E. CHIEF ENGINEER	DATE	INITIALS	
	DATE: 7/1/09	6/18/09	J.E.C.	
				STANDARD NO. S-12